

Energy Storage, DER, and Microgrid Project Valuation

EPRI DER-VET™ Analysis in Action

Eva Gardow

evgardow@epri.com

Technical Executive | EPRI

January 26, 2023


The Challenges of Storage, DER*, & Microgrid Modeling

- Today's energy storage, DER, and microgrid deployments demand robust analysis for strategic planning
- Valuation of energy storage requires project-level analyses for specific applications and locations
- This is a complex co-optimization, decision-making process

EPRI's Distributed Energy Resources Value Estimation Tool, DER-VET™ addresses these challenges

^{*}DER: Distributed Energy Resources

The Solution: EPRI's DER-VET™



Bridges industry gaps in projectlevel energy storage, DER, and microgrid analysis with a publicly available tool and methodology

Creates a common and consistent communication tool among stakeholders

Evaluates various perspectives from customers values to grid values in any market; estimates benefits and costs of energy storage and other DER

DER-VET™ provides an open-source platform for calculating, understanding, and optimizing the value of DER based on their technical merits and constraints: <u>www.der-vet.com</u>

DER-VET's Past, Present, and Future

2016EPRI StorageVET®

www.storagevet.com

2022
EPRI DER-VET™ V1.2
1,000+ Users
www.der-vet.com



2013 EPRI ESVT

Cost-Effectiveness of Energy Storage in California https://www.epri.com/research/ products/000000003002001164 **2020** EPRI DER-VET Beta

202XDER-VET User Group and Open-Source Developer Community





Distributed Energy Resource Value Estimation Tool (DER-VET™)

DER-VET™ Software Reference Cases ESIC Task Force Help Forums

To download DER-VET, go to https://www.der-vet.com/

- Download the tool for free as it was developed with California Energy Commission funding
- Software Release: DER-VET™ Version 1.2 (Updated July 11, 2022)
- DER-VET™ Overview Presentation (September 2022)
- DER VET User Guide




Get Involved

- Engage with monthly Public ESIC Task Force Web Meetings. The Energy Storage Integration Council (ESIC), an open technical forum. More info can be found at www.epri.com/esic.
- ESIC Working Group 1 DER-VET™ Task Force Meeting Recordings can be found at <u>www.der-vet.com/esictf</u>
- The ESIC collaboration site contains live draft user documentation from the ESIC DER-VET™ Subgroup at <u>collab.epri.com/esic</u>.



Technologies in DER-VET



Services in DER-VET



- Energy Time Shift
- Load Following
- Frequency Regulation
- Spinning Reserves
- Non-spinning Reserves
- Resource Adequacy Capacity



- Upgrade Deferral
- Reliability/Resilience




- Retail Energy Time Shift
- Demand Charge Reduction
- Demand Response
- Reliability/Resilience




Input and Output Examples in DER-VET

DER-VET Project Configuration Example



DER-VET Dispatch Results Example





Long Duration Energy Storage Case Study

Long Duration Energy Storage (LDES) DER-VET Analysis

Туре	Technology	Acronym	TRL
	Concrete Thermal Energy Storage	CTES	4
Gertan	Electro-Thermal Energy Storage	ETES	3
	Gravitational Energy Storage	GES	6
	Liquid Air Energy Storage	LAES	6
	Lithium-Ion Battery Storage	Li-lon	9

Base

 All technologies were run using the original pricing curves in each region for 4h for Li-Ion Benchmark as well as 6, 8, and 10h


Sensitivities

- Capital costs were adjusted +10% / -30%
- Energy prices were modified (mod) from their original (orig)
- RTE was adjusted +/- 5% points


Pricing	Orig								
RTE	Base	Base	Base	High	High	High	Low	Low	Low
Costs	Base	High	Low	Base	High	Low	Base	High	Low
Pricing	Mod								
RTE	Base	Base	Base	High	High	High	Low	Low	Base
Costs	Base	High	Low	Base	High	Low	Base	High	Base

Significant number of DER-VET cases: 1728 total

DER-VET Results: Tech Duration vs. Revenue Requirements



400-	8 hours
Yearly Energy Time Shift + A/S Revenue (\$/kw-yr)	\$-86 \$-86 \$103
Yearly E + A/S Re	\$-91=
0-	Revenue Requirement (\$/kW-yr)



Duration,	LDES	LDES	LDES	LDES	
hours	Α	В	С	D	Li-ion
4					-23
6	-93	-39	-104	-70	38
8	-91	-36	-86	-60	103
10	-88	-34	-67	-50	170

Technology cost forecast is a key driver for LDES analysis

Transmission Solar + Energy Storage Case Study

LADWP Energy Storage + Solar Project

- Los Angeles Department of Water and Power (LADWP) required to study and procure energy storage
- 100 MW, 4-hour battery energy storage system
- 200 MW solar PV
- Power Purchase Agreement (PPA) able to claim Federal Investment Tax Credit (FITC) incentive

	Provide Energy Time Shift and Spinning Reserve	Restrict Charging from Grid	Restrict Charging from Grid and Discharge Min	Provide Frequency Response
Case #1	✓		\checkmark	
Case #2	\checkmark		\checkmark	\checkmark
Case #3	\checkmark	\checkmark		
Case #4	✓	\checkmark		\checkmark


LADWP Full Report: Integrating Energy Storage System with Photovoltaic Generation: Analysis within Los Angeles Department of Water and Power (LADWP)


Service Territory to Meet SB801 Requirements at http://www.epri.com/abstracts/Pages/ProductAbstract.aspx?ProductId=000000003002013007



LADWP Case Results - Dispatch

• Impact of grid charging constraints:






DER-VET Optimized Dispatch Outputs



LADWP Case Results - CBA

 Several cases resulted in benefit-cost ratios greater than one for project start years after 2022 as illustrated in the graph below






Microgrid Design for California Public Service Power Shutoffs (PSPS) Events

Microgrid Design - DER-VET Modeling Assumptions

 Identify potential Public Safety Power Shutoff (PSPS) planned events and duration in California


 Solar PV plus battery energy storage microgrid technologies

 Initial storage state of charge at the start of outage event is 100% with advanced PSPS notifications








Load and PV Profile












Peak load – 2.16 MW 24hr load requirement – 35MWh 36hr load requirement – 48MWh 48hr load requirement – 76MWh



Microgrid Sizing Results




The energy storage and PV size corresponding to the knee point. Knee-point is a point where adding more PV does not affect the size of energy storage significantly.




Microgrid Cost Summary

LA – Sec School




Min Cost of covering 24, 36, and 48hr outage – \$5M, \$7M, and \$8M

LA - Hospital



Min Cost of covering 24, 36, and 48hr outage – \$10M, \$14M, and \$18M

SCE Feeder



Min Cost of covering 24, 36, and 48hr outage – \$12M, \$16M, and \$22M



Together...Shaping the Future of Energy®